



# CPR

## Safety and compliance for electrical cables

# Summary

What is CPR	3
When it was introduced	4
Why it is important	4
Reference technical standards	5
The main innovations introduced by the CPR for cables	6
• <i>Standardized reaction-to-fire tests</i>	6
• <i>Cable performance classification</i>	7
• <i>Additional performance classes</i>	8
• <i>CPR Classes by Installation Type</i>	9
• <i>CE marking obligation</i>	10
• <i>Declaration of Performance (DoP)</i>	11
• <i>Mandatory labelling</i>	12
• <i>AVCP Systems</i>	13
• <i>Example of CE Declaration</i>	14

# What is CPR

The CPR, acronym for **Construction Products Regulation**, is a European law that establishes harmonized requirements and the essential characteristics that all construction products, including electrical cables, designed to be permanently installed in civil engineering works must guarantee for the scope of application.

The **main objectives** of the CPR are:

- Ensure the safety of people
- Uniform product performance
- Promote free movement in the EU market



# When it was introduced

The CPR came into force on April 24th of 2011; its main provisions became mandatory from July 1st, 2013. However, it is only since July 1st of 2017 that CPR became mandatory for cables, with the introduction of EN 50575. This standard requires companies that sell and distribute cables to draw up a Declaration of Performance (DoP) for the product and affix the CE marking.

# Why it is important

Electrical cables, although they are not visible, cross the entire structure of a building. In case of fire they can spread flames, generate toxic fumes or thick smokes, cause short circuits that further fuel the fire.

The introduction of the CPR has imposed requirements considered essential for cables in the event of a fire:

## **1) Hygiene, health, and environment** (Requirement No. 3, Annex I, CPR Regulation)

- RoHS Directive
- REACH Regulation

## **2) Safety in case of fire** (Requirement No. 2, Annex I, CPR Regulation):

- Reaction to fire
- Fire resistance



However, non-CPR cables may still be used:

- In installations excluded from the scope of the CPR;
- Outside the European Union.

# Reference technical standards

The EN 50575 standard establishes the criteria for assessing the fire reaction of cables and the related test methods. It organizes performance classes but does not impose specific limits for cables nor define technical requirements for inclusion in each class.

Standard	Brief description
<b>UNI EN 13501-6:2023</b>	Fire classification of construction products and building elements - Part 6: Classification using data from reaction to fire tests on power, control and communication cables
<b>EN ISO 1716</b>	Reaction to fire tests for products - Determination of the gross heat of combustion (calorific value)
<b>EN 50399</b>	Common test methods for cables under fire conditions - Measurement of heat release and smoke production during flame spread tests - Test apparatus, procedures, and requirements
<b>IEC EN 60332-1-2</b>	Tests on electric and optical fibre cables under fire conditions - Part 1-2: Test for vertical flame propagation for a single insulated wire or cable - 1 kW flame test procedure
<b>IEC EN 60754-2</b>	Tests on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity
<b>IEC EN 61034-2</b>	Measurement of smoke density emitted by burning cables under defined conditions - Part 2: Test procedure and requirements

# THE MAIN INNOVATIONS INTRODUCED BY THE CPR FOR ELECTRIC CABLES

## Standardized reaction-to-fire tests



Before the CPR, each country used its own standards to test the fire reaction of cables. In Italy, for example, CEI 20-22 II and IEC 60332-3-24 Cat. C were used, which mainly assessed the burn length.

With the CPR, harmonized tests at the European level were introduced to evaluate the fire reaction of cables, replacing previous national standards.

Specifically, the EN 50399 standard was introduced for the classification of cables based on their reaction to fire, according to standardized parameters.

The main parameters of the EN 50399 test are:

- **THR1200s (Total Heat Release):**  
total heat released in 1200 seconds (in MJ)
- **Peak HRR (Heat Release Rate):**  
peak heat release rate (in kW)
- **FIGRA (Fire Growth Rate):**  
fire growth rate index (in W/s)








- **FS (Flame Spread):**  
flame spread length (in meters)

- **Peak SPR (Smoke Production Rate):**  
indicates the maximum rate of smoke production (in  $\text{m}^2/\text{s}$ )

- **TSP1200s (Total Smoke Production):**  
indicates the total amount of smoke emitted (in  $\text{m}^2$ )

## Cable performance classification

With the introduction of the CPR, electric cables must be classified according to their reaction to fire, based on a harmonised European scale. The performance classes are seven, identified by a letter (from F to A) followed by the subscript “ca” (cable), arranged in ascending order of performance. This classification takes into account several requirements related to cable behaviour in the event of fire, including flame propagation and the amount of smoke generated.

Class	Meaning	Performance	Tests to be carried out
Fca	Not subjected to the fire propagation test or they do not pass it		
Eca	<b>Minimum flame resistance</b> They only pass the single-cable flame propagation test		CEI EN 60331-1-2
Dca	<b>Moderate propagation</b> They pass the single-cable and bundle flame-propagation tests, with no stringent limits on the extent of material burning		CEI EN 60331-1-2 CEI EN 50399
Cca	<b>Good reaction to fire</b> They pass both the single-cable and bundle tests, ensuring effective limitation of fire propagation		CEI EN 60331-1-2 CEI EN 50399
B2ca	<b>High reaction to fire</b> They meet more stringent requirements in both the single-cable and bundle fire-reaction tests		CEI EN 60331-1-2 CEI EN 50399
B1ca	<b>Very high reaction to fire</b> They provide a minimal contribution to combustion, with particularly stringent requirements in the fire-reaction tests		CEI EN 60331-1-2 CEI EN 50399
Aca	Non-combustible		EN ISO 1176

In addition to the main classification (from Fca to Aca), the CPR includes complementary parameters that assess key aspects of fire safety:



### **s: SMOKE (Smoke production)**

Measures the quantity and opacity of the smoke generated, which can impair visibility and safety during evacuation in case of fire. Depending on the value reached, three classes are defined:

- s1 = low smoke production and slow smoke propagation (LSZH cables)
  - s1a: transmittance  $\geq 80\%$  (EN 61034-2)
  - s1b: transmittance between 60% and 80%
- s2 = intermediate smoke production (PVC cables by Specialcavi)
- s3 = high smoke production (not classified as s1 or s2)



### **d: DROP (Droplets of flaming particles)**

Assesses the presence of flaming droplets or particles that could contribute to fire spread.

- d0 = no flaming droplets or particles (during a 20-minute test)
- d1 = presence of persistent droplets that self-extinguish within 10 seconds
- d2 = does not meet the criteria for d0 or d1



### **a: ACIDITY (Acidity and corrosivity of gases)**

Measures the aggressiveness of gases released in terms of acidity and conductivity, which can be harmful to people and equipment.

- a1 = very low acidity (pH  $> 4.3$  and conductivity  $< 2.5 \mu\text{S}/\text{mm}$ )
- a2 = low acidity (conductivity  $< 10 \mu\text{S}/\text{mm}$ )
- a3 = higher acidity (does not meet a1 or a2 criteria)

If the test is not performed and/or not passed, the cable falls into this class (e.g., if any cable component is made of PVC, it will typically be classified as a3).

## CPR Classes by Installation Type

The choice of CPR class for electrical cables depends on the type of building, the crowd density, and the ease of evacuation in case of fire.

The CPR does not directly impose which class must be used in a specific location: it is up to each Member State to define minimum requirements. In Italy, the CEI UNEL 35016 standard has adopted very strict criteria (Italy is among the most stringent countries), and it never includes the Dca class. The CPR classes provided in Italy by CEI UNEL 35016 are:

Risk level	Typical places	CPR class required
<b>HIGH</b>	<ul style="list-style-type: none"> <li>• Airports</li> <li>• Railway stations</li> <li>• Maritime terminals</li> <li>• Subways</li> <li>• Road tunnels longer than 500 meters</li> <li>• Railways longer than 1000 meters</li> </ul>	<b>B2ca - s1a, d1, a1</b>
<b>MEDIUM</b>	<ul style="list-style-type: none"> <li>• Public buildings with high occupancy</li> <li>• Entertainment venues</li> <li>• Hospitals</li> <li>• Hotels</li> <li>• Companies and offices with more than 300 people present</li> <li>• Schools</li> <li>• Residential buildings with a fire height exceeding 24 meters</li> </ul>	<b>Cca - s1b, d1, a1</b>
<b>LOW (bundled installation)</b>	<p>Small to medium-sized public-access buildings (under 24 meters in height), such as:</p> <ul style="list-style-type: none"> <li>• Bars</li> <li>• Restaurants</li> <li>• Waiting rooms</li> <li>• Medical offices</li> </ul>	<b>Cca - s3, d1, a3</b>
<b>LOW (single-layer installation)</b>	<ul style="list-style-type: none"> <li>• Residential buildings</li> </ul>	<b>At least Eca (preferably Dca)</b>

Fca or unclassified classes are not permitted for permanent installations in buildings.

Since July 1, 2017, with the entry into force of the CPR for cables, it has become mandatory to affix the CE marking on all cables placed on the European Union market. The marking:

- ★ Confirms the product's compliance with the declared performance, particularly regarding reaction to fire;
- ★ Ensures transparency, traceability, and safety;
- ★ It's a mandatory condition for the commercialization of cables intended for fixed installations.

Through the CE marking, the manufacturer declares that a product is consistent with its Declaration of Performance (DoP). To this end, the marking must include the following information:

- Identification number of the notified body (if required for conformity assessment);
- Name or trademark of the manufacturer or distributor;
- Reaction to fire class;
- Other relevant characteristics (e.g., "rated voltage", "temperature rating", etc.).

Without the CE marking, a cable cannot be legally placed on the market for fixed installations in buildings.

### Specialcavi marking for a CPR-compliant cable:

**<meters> CE 0987 SPECIALCAVI BALDASSARI FG16OH2R16AR16 <formation> 0,6/1kV  
IEC 60332-3-24 Cca-s2,d0,a3 <lot> <yeat>**

In addition to the CE marking, voluntary quality marks may also be affixed to cables, provided that:

- They do not replace or cause confusion with the CE marking;
- They do not certify compliance with the essential requirements of the CPR;
- They serve a different purpose, such as guaranteeing quality, safety, or compliance with national standards.

Among the voluntary marks is the *HAR mark* (*Harmonized Approval for Cables*), a European mark that certifies the conformity of cables with the harmonized EN product standards, and the *IMQ mark* (*Italian Institute for Quality Mark*), one of the best-known marks in Italy for the certification of safety and quality of electrical products.

## Declaration of Performance (DoP)

The **Declaration of Performance** is a mandatory document that every manufacturer must prepare for each product or product family subject to the CPR.

The DoP must also be a public document, easily accessible, prepared regardless of the declared performance level, retained by the manufacturer for 10 years, available for every cable placed on the market, provided in paper or electronic format, and written in the languages of the countries where the cable is sold.

FG16OH2R16AR16		DICHIARAZIONE DI PRESTAZIONE N° 25D2	
Numero di tipo, lotto, serie o qualsiasi altro elemento che consenta l'identificazione del prodotto	2	FG16OH2R16AR16 Gamma: sezione da 0,50 a 240 mm <sup>2</sup>   diametro esterno da 5,8 a 75,0 mm Numero lotto: secondo quanto indicato su cavo, cartellino identificativo e DDT	
Prestazioni dichiarate	4	Codice identificativo del prodotto: FG16OH2R16AR16 Classe di reazione al fuoco: Cca-s2,d0,a3 Sostanze pericolose: Nessuna Specifica tecnica armonizzata: EN 50575:2014+A1:2016	
Sistema di valutazione e verifica di costanza delle prestazioni del prodotto		Sistema AVCP 1+	
Ente certificatore di prodotto notificato	5	LAPI S.p.A. 0987 ha eseguito la determinazione del tipo di prodotto, l'ispezione iniziale dell'impianto di produzione e del FPC, la sorveglianza continua, verifica e valutazione del FPC e il collaudo ispettivo dei campioni presi prima di immettere il prodotto sul mercato e pubblica il certificato di costanza di prestazione 0987-CPR-292	
Uso previsto del prodotto	3	CAVI PER ENERGIA, SEGNALAZIONE E COMANDO O TRASMISSIONE DATI con l'obiettivo di limitare la produzione e la diffusione di fuoco e fumo	
Ragione sociale del produttore	1	SPECIALCAVI BALDASSARI S.r.l. Via G. Pieraccini 76 - 55012 Capannori (LU) - Italy Tel. +39 0583 935741 / Fax 0583 429474 cpr@specialcavi.it / www.specialcavi.it/dop	
La prestazione del prodotto sopra identificato è conforme all'insieme delle prestazioni dichiarate. Questa dichiarazione di prestazione è stata redatta sotto l'esclusiva responsabilità del produttore sopra identificato.			
SPECIALCAVI BALDASSARI S.r.l. Azienda con sistema qualità certificato UNI EN ISO 9001: 2015 N° certificato 9125 SPEB		6 Capannori, 01/01/2024 Firmato a nome e per conto del produttore da Marco Baldassari Amministratore Delegato <i>Marco Baldassari</i>	

According to Annex III of the CPR Regulation, the DoP must include:

1. identification of the manufacturer
2. identification of the product
3. cable performance
4. cable of the product
5. notify body identification number
6. date and signature of the manufacturer

All Declaration of Performance of Specialcavi products are available online: [www.specialcavi.it/dop](http://www.specialcavi.it/dop)

## Mandatory labelling

Each cable subject to the CPR must be accompanied by a clear, legible, and indelible label or marking on the packaging, allowing its compliance to be identified.

If it is not possible to display this information directly on the cable due to space limitations, it must be present on the label, reel, drum, box, or packaging.

The information to be included on the label is:

1. Name and location of the manufacturer
2. CE marking
3. N° of identification of the CE Notified Body
4. Cable designation code
5. European CPR reference standard
6. DoP number
7. Reaction to fire class
8. Year of first production with CE marking
9. Intended use of the product according to the European Standard
10. Production lot for traceability

**SPECIALCAVI**  
WE BRIDGE PEOPLE

1 Via Pieraccini, 76 55012 Capannori (LU) - Italy  
www.specialcavi.it/dop

2 **CE**

3 EN 50575:2016 0987

4 **CAVO FTG18M19 1X4,00 PH120 IMQ - EFP B2ca**

9 **CABLES FOR POWER, SIGNALLING AND CONTROL OR DATA TRANSMISSION WITH THE OBJECTIVE OF LIMITING THE GENERATING AND SPREAD OF FIRE AND SMOKE**

6 **DoP:35A0 - Year:21 - Reaction to fire:B2ca - s1a,d1,a1** 7

**DANGEROUS SUBSTANCES: NONE**

**Drum's n.:**  
**Lot.:** K05F5 10  
**Mts:** 2000

**Date:** 23/07/2025  
**Y./Ref.:** 233  
**Operator:** 120

**Customer XXXX Area Y**

8

Barcode: BOB 01234567

The AVCP system (Assessment and Verification of Constancy of Performance) defines the level of control required to ensure that the declared performance of a cable remains consistent over time.

AVCP systems also define the degree of involvement of Notified Bodies (third-party organizations):

### **AVCP 1+ System**

It is mandatory for classes Aca, B1ca, B2ca, and Cca. It includes the following requirements:

- **initial type testing** by a Notify Body, which takes a sample at the time the prototype is produced;
- **ongoing surveillance** of the manufacturing process;
- **biannual inspection visits**, during which the Notified Body performs document checks on raw materials, verifies ISO 9001 compliance (including conformity and complaints), and inspects instrument calibration;
- **annual full-scale testing** on at least one certified cable;
- **triennial inspection** with cables' random sampling from the warehouse for each certificate under System 1.

### **AVCP 3 System**

It applies to **Dca** and **Eca** classes. It includes:

- initial product testing by a notified laboratory;
- no ongoing surveillance.

### **AVCP 4 System**

It applies to Fca class. It includes:

- a self-declaration by the manufacturer;
- no involvement of third-party bodies.

## Example of CE Declaration

# FG16OH2R16AR16

EN /EU DECLARATION OF CONFORMITY  
DE /EU KONFORMITÄTSERKLÄRUNG FR  
/DECLARATION UE DE CONFORMITÉ IT  
/DICHIARAZIONE DI CONFORMITÀ UE



EN / Issuer's name and address  
DE / Emittenten name und anschrift  
FR / Nom et adresse de l'émetteur  
IT / Nome e indirizzo dell'emittente

Specialcavi Baldassari S.r.l.  
Via G. Pieraccini, 76 - 55012 Capannori (LU) - IT

EN / This declaration of conformity is issued under the unique responsibility of the manufacturer.  
DE / Diese Konformitätserklärung ist unter der einzigartigen Verantwortung des Herstellers ausgestellt.  
FR / Cette déclaration de conformité est établie sous la responsabilité unique du fabricant.  
IT / La presente dichiarazione di conformità è rilasciata sotto la responsabilità esclusiva del produttore.

EN / Type designation  
DE / Typenbezeichnung  
FR / Désignation de type  
IT / Denominazione del tipo

FG16OH2R16AR16

EN / The product is in conformity with the European Directive  
DE / Das Produkt ist in Übereinstimmung mit der EU-Richtlinie  
FR / Le produit est conforme à la Directive Européenne  
IT / Il prodotto è conforme alla Direttiva Europea

Low voltage directive: 2014/35/EU  
RoHS: 2011/65/EU and 2015/863/UE  
REACH: REGULATION N°1907/2006  
CONSTRUCTION PRODUCT REGULATION: CPR EU 2011/305

EN / The product to which this declaration relates complies with the following normative references:  
DE / Das Produkt, auf das sich diese Erklärung bezieht, stimmt mit den folgenden normativen Verweisen überein:  
FR / Le produit auquel se réfère cette déclaration est conforme aux références normatives suivantes:  
IT / Il prodotto a cui questa dichiarazione si riferisce è conforme ai seguenti riferimenti normativi:

Conductor	CEI 20-29 EN IEC 60228
Insulation and sheath	CEI 20-11
Product standard	CEI 20-13 P.Q.A.
CPR standard for reaction to fire	EN 50399
Reaction to fire class	EN 50575:2014+A1:2016 Cca-s2,d0,a3
Flame retardant	IEC 60332-1-2 IEC 60332-3-24 (Cat C) IEC 60332-3-25 (Cat D)
Low temperature resistant	EN 60811-504+505+506
Presence of water	HD 60364-5-54:2009 [AD7]

SPECIALCAVI BALDASSARI S.r.l.  
Company with certified quality management system  
UNI EN ISO 9001: 2015 - Certificate N° 9125 SPEB

Capannori, 01/01/2025  
Alleingeschäftsführer / Chief Executive Officer  
Administrateur unique, / Amministratore unico

Marco Baldassari



**SPECIALCAVI BALDASSARI S.R.L.**

Via G. Pieraccini, 76 55012 Capannori LUCCA

Tel. +39 0583 935741 - Fax. +39 0583 429474

**[areatecnica@specialcavi.it](mailto:areatecnica@specialcavi.it)**